

**ENGINEERING DEPARTMENT
UNIVERSITY OF DELHI
DELHI-110007**

Ref. No. UE/ 160

/DU/EM-10 (2016-2017)

dated 17.8.16

NOTICE INVITING QUOTATIONS

Sealed item rate quotations are hereby invited two envelop system one for eligibility and second for financial bid from the contractor enlisted with CPWD, MES, Railways and working contractor of Delhi University for: **Provision of providing black board fitting and other allied electrical work in Faculty of Management Studies, University of Delhi** So as to reach the office of the undersigned upto 3.00 P.M. on 22/8/16

| Sl. No. | Item | Unit | Qty | Rate | Amount |
|---------|--|------|-----|--------------|------------|
| 1 | S/F DLP UPVC trunking of 105 mm X 50 mm compartment with cover clip on separates partition left, right, top internal angle, flat angle raise function, flat function cover to body joints mosaic clip & support from mosaic isolation bracket 2mm thick plastic. | mtr | 30 | | Rs. |
| 2 | S/F/Testing & commissioning of pre wired LED single box type fitting (1x20watts) for black board with reflector, complete with all accessories and one 20 watt tube (stellar bright) of 2100 lumen, 6500k etc. directly on ceiling or wall i/c connection with 1.5 sqmm FR PVC copper cond. cable etc. as read. (TMC 501 P1xT-LED 20W P 3241) (Philips make) | Nos. | 24 | | Rs. |
| 3 | S/I/T/C of 20 watts Retrofite LED Tube suitable of existing single box type fitting | Nos. | 35 | | Rs. |
| 4 | Servicing of the existing LT panel by replacing the defective parts like thimbles, insulators and nut bolts i/c painting with enamel paint by spray paint by manual or machine of approved quality two or more coat. The surface should be prepare by rubbing with sand paper then apply paint upto original finish i/c numbering of in comer and outgoing etc. as reqd. | Nos. | 1 | | Rs. |
| 5 | S/F 250amps MCCB 3 pole (25 KA D Sine DN 1-250) series i/c connection etc. as reqd. at site. (L&T make) | Nos. | 1 | | Rs. |
| 6 | P/f ceiling circular LED fitting 10/12 watts for surface mounting i/c connection etc. as reqd. | Nos. | 8 | | Rs. |
| 7 | S/f bakelite sheet of following size i/c cutting the hole for existing switch & socket etc. as reqd. | | | | |
| a) | 9"x11" of 3mm thick | Nos. | 5 | | Rs. |
| b) | 8"x5" of 3mm thick | Nos. | 5 | | Rs. |
| c) | 5"x5" of 3mm thick | Nos. | 5 | | Rs. |
| d) | T Cover | Nos. | 30 | | Rs. |
| 8 | S/F tinny trip AC box complete with all accessories with plug and top having 1 Nos. 25 ams G-Series SP MCB on surface or recess i/c making connection etc. as required. | Nos. | 6 | | Rs. |
| 9 | Supplying and fixing suitable size G.I. box with modular plate and cover in front on surface or in recess, including providing and fixing RJ-45 connection etc. as required. | Nos. | 15 | | Rs. |
| 10 | Supplying and fixing of following sizes of PVC conduit/ batten along with accessories in surface/recess including painting in case of surface conduit, or cutting the wall and making good the same in case of recessed conduit as required. 25 mm (AKG /BEC) | mtr | 80 | | Rs. |
| 11 | Supplying and fixing 3 pin, 5 amps ceiling rose on the existing junction box /wooden block including connection etc. as reqd. | Nos. | 10 | | Rs. |
| 12 | Supplying and drawing following of FR PVC insulated copper conductor, single core cable in the existing surface/recessed steel /PVC conduit as required. | | | | |
| a) | 2 x 4 sq.mm | mtr | 50 | | Rs. |
| b) | 1 x 1.5 sq.mm | mtr | 150 | | Rs. |
| c) | 2 x 6 sq.mm | mtr | 100 | | Rs. |
| d) | Cat-6 Internet Wire | mtr | 200 | | Rs. |
| 13 | Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required. | | | | |
| a) | 6 pin 15/16 amps socket | Nos. | 12 | | Rs. |
| 14 | Supplying and fixing of 1 or 2 Module (75 x 75mm) G.I. box along with modular base & cover plate for modular switches on surface/recess etc. as required. | Nos. | 12 | | Rs. |
| | | | | Total | Rs. |

Specific make

Wire : Finolex/Skytone/ Havells/RR Kabel
 Switch/socket : North-West/ Legrand/ Seimens
 PVC conduit/ Battebn : AKG/ BEC/Polvcab
 SP MCB/ DP/ FP : Hagger/ Seimens/ ABB/ L&T/ Legrand
 DLP Trunking : Legrand
 Pole Box : Syntex
 Light Fitting : Philips/ Polycab/ HPL

Condition:

- The work should be completed in 15 days.
- Rates should be quoted both in words & figures.
- CPWD specification in force will be followed.
- Contractor shall enclose copies of labour license registration with EPFO and ESIC other wise their quotation will not be accepted.
- Undersigned reserves the authority to reject any or all the quotation without assigning any reason therefore.

Executive Engineer

Undertaking:

I/we hereby undertake that my/our agency have not been black listed/debarred in any Govt. organization since last 3 years.

(Contractor)

Copy to:-

- The Director, Computer Center with a request to display the Notice Inviting Quotation on the Delhi University Website.
- Sh. S.B. Tyagi, A.E. (E)
- Sh. Devendra Kumar, J.E. (E)
- Mrs. Kavita, JACT to ensure the display of the quotation notice on University website.
- Notice Board

Executive Engineer