

ENGINEERING DEPARTMENT
UNIVERSITY OF DELHI
DELHI-110007

Ref. No. UE/

34

/DU/EM- 54 (2015-2016)

dated 21/8/15

NOTICE INVITING SPOT QUOTATIONS

Sealed item rate spot quotation are hereby invited from the contractor enlisted with CPWD, MES, Railways and working contractor of Delhi University for the work "Providing and fixing exhaust fan & electric work to be carried out at A-3 29/31 Probyn Road Security Guard room & Servent Quarter, University of Delhi. So as to reach the office of the undersigned upto 3.00 P.M. on..... 21/8/15

Sl. No.	Item	Qty	Unit	Rate	Amount
1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required. Group B	20	Nos.		Rs.
2	Supplying and fixing following way prewired SP&N MCB distribution board of steel sheet for 240 volts on surface/ recess complete with loose wire box, terminal connectors for all incoming and outgoing circuits, duly prewired with suitable size FRLS PVC insulated copper conductor up to terminal blocks, tinned copper bus bar, neutral link, earth bar, din bar, detachable gland plate, interconnections, powder painted including earthing etc. as required. (But without MCB/ RCCB/ Isolator) 2 + 8 way, Double door	2	Nos.		Rs.
3	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required. Single Pole	16	Nos.		Rs.
4	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required. 63 amps	2	each		Rs.
5	Supplying and fixing of following sizes of medium class PVC conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.				
a)	25 mm				
b)	20 mm	100	mtr		Rs.
6	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel / PVC conduit as required.	100	mtr		Rs.
a)	1 x 1.5 sq. mm				
b)	2 x 2.5 sq. mm	300	mtr		Rs.
c)	2 x 4 sq. mm	100	mtr		Rs.
7	S/F Fancy lights/ wall bracket with glass globe suitable for 60/100 watts GLS lamp i/c connection etc. as reqd. at site	200	mtr		Rs.
		6	Nos.		Rs.
8	S/F/I testing and commissioning of pre wired fluroscet fitting single box type fitting(1x40W) complete with all accessories and tube etc. as reqd. ceiling or wall i/c connection with 1.5sqmmm FR PVC cond. Cable etc. as reqd. (TMC 501/136LPP) (Philips make)	6	each		Rs.
9	S/F 3 module power box with screw less decorative plate modular having 1 Nos. switch 15/16 amps and 1 Nos. socket 6 pin 15/16 amps making connection etc. as reqd.	2	Nos.		Rs.
10	S/F 6 module power box with screw less decorative plate modular having 2 Nos. switch 15/16 amps and 2 Nos. socket 6 pin 15/16 amps making connection etc. as reqd.	8	Nos.		Rs.
11	Supplying and fixing stepped type electronic fan regulator on the existing modular plate switch box including connections but excluding modular plate etc. as required.	4	Nos.		Rs.
12	Supplying and fixing brass batten/ angle holder including connection etc. as required.	6	Nos.		Rs.
13	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.				
a)	5/6 amps switch				
b)	3 pin 5/6 amps socket outlet	6	Nos.		Rs.
14	S/F 1 No. RJ-11, 13 module box i/c modular plate & covering in front on surface connection etc. as reqd.	6	Nos.		Rs.
		6	each		Rs.
15	S/F CAT- 6 wire for Data outlet in the existing conduit etc. as reqd.	200	mtr		Rs.

fabrication, installation, testing & commissioning of double doors feeder pillar vertical design panel wall mounted 3 phase 4 wire system 415V, AC supply. The panel hard shall be made out of 16 SWG CRCA sheet duly painted i/c making foundation of F.P. The doors shall be made out of 16 SWG sheet vermin & dust parried, LED indication lamp, digital volt & Amp meter at all I/P & O/P MCCBs & having fixing for following items. Incomer 100 amps MCCB 25 KA 01 NO. OUTgoing 100 amps 4 pole isolator & 63 amps DP 3 Nos. Bus bar 600 amps (Aluminum)		1	each	Rs.
17	S/I/T/C of 12" heavy duty exhaust fan with suitable size louver shutter i/c wooden work if reqd.	4	each	Rs.
18	P/f of 1 HP pressure pump, single 230 volts AC supply complete with all accessories i/c making on chain pully arrangement and labour etc. as reqd. at site.	1	each	Rs.
19	S/F 100 amps 3 pole 35 KA (LM) MCCB on surface or in recess i/c making connection etc. as reqd. (Legrand)	1	each	Rs.
20	Fixing geizer 25 ltr 220 volts with fastner including copper pipe making connection etc: as reqd.	5	each	Rs.
				Total
				Rs.

Condition:

- 1 The work should be completed in 7 days
- 2 Rates should be quoted both in words & figures.
- 3 CPWD specification in force will be followed.
- 4 Undersigned reserves the authority to reject any or all the quotation without assigning any reason therefore.

Executive Engineer

Undertaking:
 I/we hereby undertake that my/our agency have not been black listed/debarred in any Govt. organization since last 3 years.

(Contractor)

Copy to:-

- 1 The Director, Computer Center with a request to display the Notice Inviting Tender on the Delhi University Website.
- 2 Sh. S.M. Goel, J.E. (E)
- 3 Mrs. Kavita, JACT to ensure the display of the tender notice on University website.
- 4 Notice Board


 Executive Engineer