

ENGINEERING DEPARTMENT

UNIVERSITY OF DELHI

DELHI-110007

/DU/EM- (2015-2016)

dated

24/8/15

Ref. No. UE/

37

NOTICE INVITING QUOTATIONS

Sealed item rate quotation are hereby invited from the contractor enlisted with CPWD, MES, Railways and working contractor of Delhi University for the work "Minor electrical work to be carried out in newly constructed store room at DUCC, University of Delhi. 'So as to reach the office of the undersigned upto 3.00 P.M. on.....26/08/15

Sl. No.	Item	Qty	Unit	Rate	Amount
1	S/F/I testing and commissioning of pre wired fluroscnet fitting double box type fitting (2x36W) complete with all accessories and tube etc. as reqd. directly on ceiling or wall i/c connection with 1.5 sqmm FR PVC cond. Cable etc. as reqd (TMC/501 2X TLD 36W EBE) (Philips make)	4	Nos.		Rs.
2	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required. Group B	7	Nos.		Rs.
3	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel / PVC conduit as required.				
a)	1x1.5 sq. mm	20	mtr		Rs.
b)	2 x 2.5 sq. mm	20	mtr		Rs.
4	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.				
a)	5/6 amps switch	1	Nos.		Rs.
b)	3 pin 5/6 amps socket	1	Nos.		Rs.
5	Supplying and fixing of following sizes of medium class PVC conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.				
a)	25 mm	16	mtr		Rs.
6	Supplying and fixing 2 module stepped type electronic fan regulator on the existing modular plate switch box including connections but excluding modular plate etc. as required.	3	Nos.		Rs.
7	Supplying and fixing following way prewired SP&N MCB distribution board of steel sheet for 240 volts on surface/ recess complete with loose wire box, terminal connectors for all incoming and outgoing circuits, duly prewired with suitable size FRLS PVC insulated copper conductor up to terminal blocks, tinned copper bus bar, neutral link, earth bar, din bar, detachable gland plate, interconnections, powder painted including earthing etc. as required. (But without MCB/ RCCB/ Isolator) 2 + 8 way, Double door	1	Nos.		Rs.
8	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required. Single pole	6	Nos.		Rs.
9	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required. 63 amps	2	each		Rs.
10	Supplying and making end termination with brass compression gland and aluminum lugs for following sizes of PVC insulated and PVC sheathed /XLPE aluminum cond. Cable of 1.1 KV grade etc. as reqd.				
a)	2c x 16 sqmm	2	each		Rs.
11	S/F 15" exhaust fan complete with all accessories i/c making connections and suitable louver shutter etc. as reqd.	1	Nos.		Rs.
12	S/F of fan hook heavy duty after exposing lenter road and jaming the same with cement concrete etc. as reqd.	2	Nos.		Rs.
13	S/F /laying of 2c x 16sqmm XLPE insulated & PVC sheathed aluminum conductor anamoured power cable in ground i/c excavation, sand cushioning protective covering & making good the same etc. as reqd.	20	mtr		Rs.
Total					Rs.

Specific make:

Wire : Finolex/ Skytone/ RR Kabel

SP MCCB/ Isolator : Legrand/ Hagger

Switch, socket/sheet

/ Boxes/ Fan Regulator : North-West

Light Fitting : Philips

DLP Trunking : Legrand

Condition

- The work should be completed in 5 days
- Rates should be quoted both in words & figures.
- CPWD specification in force will be followed.
- Undersigned reserves the authority to reject any or all the quotation without assigning any reason therefore.

Executive Engineer

Undertaking:

I/we hereby undertake that my/our agency have not been black listed/debarred in any Govt. organization since last 3 years.

(Contractor)

Copy to:-

- The Director, Computer Center with a request to display the Notice Inviting Tender on the Delhi University Website.
- Sh. S.M. Goel, J.E. (E)
- Mrs. Kavita, JACT to ensure the display of the tender notice on University website.
- Notice Board

Executive Engineer