

**ENGINEERING DEPARTMENT
UNIVERSITY OF DELHI
DELHI-110007
NOTICE INVITING QUOTATIONS**

dt. 4-01-16

Ref. No. UE/ 65 /DU/EM-

(2015-2016)

Sealed item rate quotation are hereby invited two envelop system one for eligibilty and second for financial bid from the contractor enlisted with CPWD,MES,railways and working contractor of Delhi University for the work:**Electrical work to be carried out in Lab No-112 at Zoology Department , University of Delhi.**So as to reach the office of the undersigned upto 3.00 P.M. on *27/01/16*.


S. No	Unit	Qty	Unit	Rate	Amount
1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.	Nos	5		
2	Rewiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable and 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable as earth wire in existing surface/ recessed steel/PVC conduit including dismantling as required.	Nos	12		
3	S/f following modular switch/socket on the existing modular plate & switch box including connection but excluding modular plate etc as reqd.				
a	5 amp switch	Nos	15		
b	5 amp socket	Nos	3		
c	15 Amp switch	Nos	20		
d	15 Amp socket	Nos	20		
e	fan regulator	Nos	4		
4	S/F following sizes of PVC conduit along with accessories in S/F including cutting the wall and making good the same in case of recessed conduit as reqd.				
a	25 mm	Mtr	40		
5	S/F of PVC DLP of following size with complete acssecories i/c joints, tee, seperator etc as required at site.				
a	105mmx50mm	Mtr	40		
6	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel / PVC conduit as required				
a	1x1.5	mtrs	400		
b	2x2.5	Mtrs	50		
c	2x4	Mtrs	250		
d	2x6	Mtrs	100		
e	4X10+2X10 SQMM	Mtr	20		
7	Supply/Testing and commissoing of 2x40 watt Tube light fitting complete with all accessories having 2 nos flurosent tube i/c making connection etc as reqd at site. TMC 501/236	Nos	8		
8	Supplying and fixing of following ways surface/ recess mounting, vertical type, 415 volts, TPN MCB distribution board of sheet steel, dust protected, duly powder painted, inclusive of 200 amps tinned copper bus bar, common neutral link, earth bar, din bar formounting MCB's (but without MCB's and incomer) as required .				
a	12 way(4+36), Double Door	Nos	1		
9	S/F 100 amps MCCB of 3 pole 10 Ka in the existing feeder pillar/panel i/c connection etc as reqd at site.	Nos	1		

10	Supplying and fixing 5 amps to 32 amps rating ,240 Volts, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc as reqd.	Nos	36
11	Supplying and fixing following size/ modules, GI box along with modular base & cover plate for modular switches in recess etc as required.		
a	6 Module	Nos	10
b	12 Module	Nos	3
12	S/F Tiny Trip AC box complete with all accessories with plug and top on surface/recessed & making good the same etc as at site & 1 nos 32 amps G series SP MCB etc as reqd at site.	Nos	3

Total

Specific make:-
 fitting:- phillips
 wire:- Skytone/Havells/Finolex
 Switch/socket/boxes:- North-west/Legrand/Clipsal
 MCBDB:- Legrand/HavellsHagger
 DLP trunking:-Legrand

- Conditions:-1. The Work is to be complete within 10 days.
 2. CPWD specification should be followed
 3. Contractor shall enclose the copies of labour license registration with EPFO, ESIC otherwise their quottaion will not be accepted.
 4. Undersigned reserves the authority to reject any or all the quottaion without assigning any reason therefore.


 Executive Engineer

Undertaking:

I/we hereby undertake that my/our agency have not been black listed/debarred in any Govt. organization since <p align="center">(Contractor)</p>

Copy to :-

1. The Director, Computer centre with a request to display the Notice Inviting Quotation on the Delhi University website.
- 2.Sh. Abhay J. Tirkey, J.E (E)
- ✓ 3.Mrs. Kavita , JACT to ensure the display of the tender notice on University website.
- 4.Notice Board.